



COUNTY OF CHARLOTTE PURCHASING DIVISION

Charlotte County Administration Center
18500 Murdock Circle
Port Charlotte, Florida 33948-1094
(941) 743-1378

TO: PROSPECTIVE BIDDERS

DATE: June 19, 2025

RE: ADDENDUM #1 BID NO. 20250439 STORMWATER COLLECTION SYSTEM REHABILITATION – ANNUAL CONTRACT

BID DUE DATE: 2:00 p.m. (EST) JULY 23, 2025

Bidders are hereby notified that this Addendum shall be made a part of the above-name proposal and contract documents. The intent is to add to, modify, or clarify the documents. Should any of these items have an effect on price, such changes shall be included in the price quote. These items have the same force and effect as if contained in the original bid.

ITEM #1 QUESTION/ANSWER

- Q1:** Would the owner consider United Felts an approved CIPP Liner manufacturer per Section TS-11-B?
A1: Yes, if the product meets or exceeds the specifications listed in the bid package.
- Q2:** Would the owner consider Quadex GeoKrete, an approved lining system, for pipe diameters 36in and above in lieu of CIPP?
A2: No, this contract is for CIPP only.

ITEM #2 BID DUE DATE HAS BEEN CHANGED TO JULY 23, 2025, AT 2:00 p.m. (EST)

This addendum is binding and is to be considered as if contained within the original bid documents of Bid No. 20250439. Bidders are required to acknowledge receipt of this addendum on their bid forms.

Kimberly Corbett

Kimberly A. Corbett, C.P.M., CPPB
Senior Division Manager-Purchasing

cc: File



COUNTY OF CHARLOTTE PURCHASING DIVISION

Charlotte County Administration Center
18500 Murdock Circle
Port Charlotte, Florida 33948-1094
(941) 743-1378

TO: PROSPECTIVE BIDDERS

DATE: June 25, 2025

RE: ADDENDUM #2 BID NO. 20250439 STORMWATER COLLECTION SYSTEM REHABILITATION – ANNUAL CONTRACT

BID DUE DATE: 2:00 p.m. (EST) JULY 23, 2025

Bidders are hereby notified that this Addendum shall be made a part of the above-name proposal and contract documents. The intent is to add to, modify, or clarify the documents. Should any of these items have an effect on price, such changes shall be included in the price quote. These items have the same force and effect as if contained in the original bid.

ITEM #1 QUESTION/ANSWER

- Q1:** Will owner except standard Polyester resin in instead of Vinyl Ester resin? Vinyl Ester resin is usually reserved for pressure pipe or chemical exposure applications?
A1: Refer to Page 17, GP-03, LL in the bid package.
- Q2:** Is UV CIPP ASTM 2019 acceptable for this contract?
A2: No, this is not acceptable for this contract.
- Q3:** Are there previous detailed, itemized bid tabs for this or similar past lining projects?
A3: Please refer to Page 18, TS-01, C Bid Prices/Terms of Contract.
- Q4:** If Manufacturer approved, will air inversion/steam processing of liners be an acceptable installation and liner processing method?
A4: Yes, this will be acceptable.
- Q5:** Does the owner have a local disposal site for debris removed from pipes during the cleaning operation?
A5: The Contractor is responsible for the debris removal and disposal as specified in the Technical Specifications.
- Q6:** Since this work is unidentified, can Maintenance of Traffic bid items such as, Lane Closure and Flaggers be added to the Bid Sheet?
A6: The Contractor is responsible for submitting MOT plans when applying for the right-of-way permit. There is no pay item for MOT.
- Q7:** If point repairs are required to facilitate lining, can a separate or alternate bid item be added to account for that work, or should it be included within the unit pricing for CIPP?
A7: No, the point repairs are to be priced separately from the cost of the CIPP lining. The estimated cost for point repairs is submitted when needed. Refer to Pages 28 and 29, Point Repairs and Estimate Procedures Sections.

This addendum is binding and is to be considered as if contained within the original bid documents of Bid No. 20250439. Bidders are required to acknowledge receipt of this addendum on their bid forms.

Kimberly Corbett

Kimberly A. Corbett, C.P.M., CPPB
Senior Division Manager-Purchasing

cc: File

Bid No. 20250439 Addenda #2



COUNTY OF CHARLOTTE PURCHASING DIVISION

Charlotte County Administration Center
18500 Murdock Circle
Port Charlotte, Florida 33948-1094
(941) 743-1378

TO: PROSPECTIVE BIDDERS

DATE: July 2, 2025

RE: ADDENDUM #3 BID NO. 20250439 STORMWATER COLLECTION SYSTEM REHABILITATION – ANNUAL CONTRACT

BID DUE DATE: 2:00 p.m. (EST) JULY 23, 2025

Bidders are hereby notified that this Addendum shall be made a part of the above-name proposal and contract documents. The intent is to add to, modify, or clarify the documents. Should any of these items have an effect on price, such changes shall be included in the price quote. These items have the same force and effect as if contained in the original bid.

ITEM #1 QUESTION/ANSWER

- Q1:** Section TS-13 speaks about the sonar specs. It states, "Above ground", ground penetrating radar is performed above ground (GPRS), Sonar is performed underwater, inside pipes generally that cannot be dewatered. Is the intention of the contract to perform Sonar or GPRS?
- A1:** As TS-13 A. General states, above ground SONAR (sound navigation and ranging) survey of the pipes size, length and condition may be deemed necessary by the Contractor upon inspection of the pipe and location. For this reason, these are listed as separate bid items.

This addendum is binding and is to be considered as if contained within the original bid documents of Bid No. 20250439. Bidders are required to acknowledge receipt of this addendum on their bid forms.

Kimberly Corbett

Kimberly A. Corbett, C.P.M., CPPB
Senior Division Manager-Purchasing

cc: File



COUNTY OF CHARLOTTE PURCHASING DIVISION

Charlotte County Administration Center
18500 Murdock Circle
Port Charlotte, Florida 33948-1094
(941) 743-1378

TO: PROSPECTIVE BIDDERS

DATE: July 9, 2025

RE: ADDENDUM #4 BID NO. 20250439 STORMWATER COLLECTION SYSTEM REHABILITATION – ANNUAL CONTRACT

BID DUE DATE: 2:00 p.m. (EST) JULY 23, 2025

Bidders are hereby notified that this Addendum shall be made a part of the above-name proposal and contract documents. The intent is to add to, modify, or clarify the documents. Should any of these items have an effect on price, such changes shall be included in the price quote. These items have the same force and effect as if contained in the original bid.

ITEM #1 QUESTION/ANSWER

- Q1:** Will the County accept UV GRP CIPP Liner or Specifically Reline America AlphLiner as an equivalent to the specified Felt Liners Insituform?
A1: The County will accept if it meets or exceeds the specifications listed in the bid package.
- Q2:** Will the County accept alternate trenchless rehabilitation technology such as structural Expand in Place PVC Liners?
A2: This contract does not have that alternate listed.
- Q3:** What are, if any, liquidated damages for this project?
A3: There are no liquidated damages for this contract.
- Q4:** Is SONAR required for the evaluation of the storm pipes or will CCTV footage from the storm pipes be sufficient?
A4: Refer to Page 31, TS-13.
- Q5:** What is the average size of work orders as far as footage and cost?
A5: Refer to Page 18, TS-01 C.
- Q6:** How many workorders per contract period does the County intend to issue?
A6: This is an annual contract, and orders are generated as needed so there is no way to determine the number of orders per contract period.
- Q7:** What is the preferred cure method of the CIPP liners, water, or steam?
A7: Refer to Page 27, TS-11.
- Q8:** What is the anticipated start date for work orders to be issued?
A8: This contract is effective October 1, 2025.

- Q9:** On the bid form are cleaning items 3, 4, and 5 to be considered separate work from the CIPP bid items, or are they to be used in conjunction with the CIPP bid items?
- A9:** They are used in conjunction with the CIPP bid items.

This addendum is binding and is to be considered as if contained within the original bid documents of Bid No. 20250439. Bidders are required to acknowledge receipt of this addendum on their bid forms.

Kimberly Corbett

Kimberly A. Corbett, C.P.M., CPPB
Senior Division Manager-Purchasing

cc: File



COUNTY OF CHARLOTTE PURCHASING DIVISION

Charlotte County Administration Center
18500 Murdock Circle
Port Charlotte, Florida 33948-1094
(941) 743-1378

TO: PROSPECTIVE BIDDERS

DATE: July 17, 2025

RE: ADDENDUM #5 BID NO. 20250439 STORMWATER COLLECTION SYSTEM REHABILITATION – ANNUAL CONTRACT

BID DUE DATE: 2:00 p.m. (EST) JULY 23, 2025

Bidders are hereby notified that this Addendum shall be made a part of the above-name proposal and contract documents. The intent is to add to, modify, or clarify the documents. Should any of these items have an effect on price, such changes shall be included in the price quote. These items have the same force and effect as if contained in the original bid.

ITEM #1 QUESTION/ANSWER

- Q1:** Line item 51 "Mobilization" has the block for "Unit Price" blacked out. The "extended price" block is open to be filled in. Will the extended price be per year of contract or per work order? If per work order, will it be able to be updated by the contractor per issuance or is it the same every time, and is there a % of the bid cap on the amount?
- A1:** The mobilization cost is a fixed rate per project/work order and remains the same for the life of the contract.
- Q2:** Will the County remove & replace any inlet tops and cones/frame & covers for installations of CIPP when needed, or does that need to be included in the mobilization price?
- A2:** This would be priced separately if required just like point repairs.

This addendum is binding and is to be considered as if contained within the original bid documents of Bid No. 20250439. Bidders are required to acknowledge receipt of this addendum on their bid forms.

Kimberly Corbett

Kimberly A. Corbett, C.P.M., CPPB
Senior Division Manager-Purchasing

cc: File